


TECHNICAL SPECIFICATIONS

NFL Nangal Case Ref. No.					SPX/2024/46
Quotation No. & Date					
Name of Bidder:					
Vendor's Complete Address :					
Vendor's Contact Details: Vendor may furnish E-Mail Id, Telephone / Mobile No. etc. alongwith complete Name & Address details of the firm for Clarifications / Placement of Order.					
Sr. No.	NFL Requirement				Vendors Comment (Agreed / If not Agreed, Please Comment)
1	Sr. No.	Material Code	Description of Material	UOM	Qty. Required
	i.	7450505	<p style="text-align: center;">Manufacture Testing & Supply of Wearing Ring Set for PC-5N/R,10N/R & 12N/R pumps</p> <p style="text-align: center;">MoC: ASTM A276 Type 316L</p> <p>Each Set consisting of 01 No. each of size:</p> <p style="text-align: center;">1.OD259.80 X ID248.00 X 25mm thk 2.OD279.30 X ID260.50 X 25mm thk 3.OD234.40 X ID222.70 X 25mm thk 4.OD279.40 X ID235.00 X 25mm thk 5.OD259.80 X ID248.00 X 25mm thk 6.OD279.30 X ID260.50 X 25mm thk</p>	SET	2.000
	ii.	7451212	<p style="text-align: center;">Throat Bush & Sleeve for PC-12N/R as per Drawing No.NG-17108</p>	NO	3.000
	iii.	7450506	<p style="text-align: center;">Throat Bush for PC-5N/R as per Drawing No.NG-12472</p>	NO	3.000
	NOTE:		<p>1. Material shall be manufactured under Third Party Inspection of M/s LRQA/TUV/BV/PDIL/EIL and the scope of Third Party Inspections shall include:-</p> <p>a) Verify Material Test Certificates for Chemical & Physical Properties (Tensile Strength, Yield Strength & Elongation at Break).</p> <p>b) Witnessing DPT & Ultrasonic testing of the material being supplied.</p> <p>c) Verification of all the dimensions as per drawing.</p> <p>2. Party shall submit all the Test Certificates verified and stamped by Third party Agency along with Inspection Release Note & Stamping Details.</p> <p>(TPI Charges if any; shall be inclusive in the quoted price)</p>		

FOLD

FOLD

S. NO NG-17108



THROAT BUSH

SEC. - X.X
SLEEVE

MATERIALS: SS 304

PASSED
Qaid
 25-10-94

SHEET OF

NATIONAL FERTILIZERS LIMITED NANGAL UNIT/EXPANSION

DGN.	—	TCD.	—	TITLE	UREA PLANT
DRN.	<i>Suljani</i> 13/19	CHKD.	<i>Qaid</i>	THROAT BUSH & SLEEVE FOR 10 PC-12/12R	
SUBM.	<i>M. K. Singh</i> 20/10	RE-CHKD.			
APPD.			<i>N. S. Singh</i> 22-11-94		
SCALE	1:1	DATE	30.9.94	DRG. NO.	5/1000/32/DD-64
REF. DRG.				REV.	

FOLD


FOLD

NG-17108

NO.	DATE	REVISIONS	APPD.

NO.	DATE	REVISIONS

S. NO. NG. 12472



MAT. = AISI 316L

PASSED FOR EXECUTION
 Signature: *W. A. J. ...*
 Designation: *...*
 Dated: *12/11/78*

SHEET OF

DGN.	TCD.	DATE 28.11.78
DRN.	CHKD.	
SUBM.	APPD.	
SCALE 1:1		

TITLE: UREA PLANT
 BUSH FOR THIRD STAGE CARBA-
 MATE RECIRCULATION PUMP
 EQPT. No PC5 & F.
 DRG. NO. 5/1000/32/DD17
 REV.

NG. 12472