

SPECIFICATION

NFL Nangal Case Ref. No.				SP/2024/8
Quotation No. & Date				
Name of Bidder:				
Vendor's Complete Address :				
Vendor's Contact Details: Vendor may furnish E-Mail Id, Telephone / Mobile No. etc. alongwith complete Name & Address details of the firm for Clarifications / Placement of Order.				
Sr. No.	NFL Requirement			Vendors Comment (Agreed / If not Agreed, Please Comment)
1	Sr. No.	Material Code	Description of Material	Qty. in No.
	i.	4840584	LINE SHFT AS PER DRG NO. 21-SP-360-1(MK-1) MOC:AISI-304.	2.00
	ii.	4840592	TOP SHAFT WITH HEX. NUT(BRONZE) AS PER DRG. NO.:21-SP-586, MOC:AISI-304.	3.00
	iii.	4840593	LINE SHAFT (MK-1) AS PER DRG. NO.: 21-SP-588, MOC:AISI-304.	3.00
	iv.	4840594	LINE SHAFT (MK-2) AS PER DRG. NO.: 21-SP-588, MOC:AISI-304.	4.00
	NOTE: i		(i) Party quote the material as per our technical specifications will be considered as technically acceptable.	
			(ii). Party shall furnish the following certificates after third party inspections of M/s. LRA/TUV/BV/EIL/PDIL:- (a) Chemical Composition (Review only) (b) Physical properties (Review only) (c) Mill test certificates for forging as per relevant ASTM standard (Review only) (d) Dimensional inspection (To be witnessed)	
			(iii). All the test certificates shall be signed and stamped from inspection party.	
			(iv) Run out of shaft should not be more than 0.02mm and party shall certify the same.	

2	Guarantee/ Warrantee Certificates	You shall have to furnish a Guarantee / Warranty Certificate for your products against defective material / bad workmanship for a period of 12 months from the date of commissioning or 18 months from the date of dispatch, whichever is earlier. In case the material fails during the above Guarantee period due to defective material or bad workmanship, you will have to replace the same free of cost. Certificate must accompany the dispatch documents	
---	--------------------------------------	---	--



KEY WAY 3.8X6X110
LONG.

S. No. **12954**

REVISIONS
No. DATE



+

+

APPD.

REVISIONS

No. DATE



HEX. NUT
SCALE: 1:2
MAT. BRONZE

KEY WAY TOLERANCE		
WIDTH	DEPTH	W ₂ ±0.02 +0.42
5.00	5.5	
TOLERANCE		D ₂ ±0.1 +0.0

PASSD BY: *[Signature]*
 Date: *18-3-94*
 Checked: *P.E. (MCC)*
 Blotter: *18-3-94*

N. F. LTD. NANGAL UNIT/EXPANSION

TITLE TOWN WATER WORKS

DGN.	TCD.
DRN. SKHAPoor	CHKD. <i>[Signature]</i>
SUBM. <i>[Signature]</i>	APPO. <i>[Signature]</i>
SCALE AS SHOWN	DATE 2-3-94

TOP SHAFT FOR 15 H.P. JOHNSTON PUMP

DRG. NO. **21-SP-586**

REV.

S. NO 12954



S.NO. 2020/2021
शेखर
एन एफ एल लिमिटेड



PASSED FOR EXECUTION
Date: 12/12/2021
Signature: [Handwritten Signature]
Initials: [Handwritten Initials]

MAT. SS 304

7/8	R.195	DIMENSIONS AND MATERIAL REVISED		
R.NO.	DATE	BRIEF RECORD		INITIALS
F. C. I. LTD. NANGAL UNIT				TOPI WATER WORKS
DGN.		CHD	TRD.	
DRN.	12/21			
SUBM.	12/21	SCALE		
		DRG. NO. 21-SP-360		

LINE SHAFT
FOR
JOHNSTON PUMP 30 HP

