




TECHNICAL SPECIFICATION

NFL Nangal Case Ref. No.				SP/2023/44
Quotation No. & Date				
Name of Bidder:				
Vendor's Complete Address :				
Vendor's Contact Details: Vendor may furnish E-Mail Id, Telephone / Mobile No. etc. alongwith complete Name & Address details of the firm for Clarifications / Placement of Order.				
Sr. No.	NFL Requirement			Vendors Comment (Agreed / If not Agreed, Please Comment)
1	Sr. No.	Material Code	Description of Material	Qty. in No.
	i.	4304231	SPARES FOR NITRIC ACID PUMPS. CASING FOR PUMP DRAWING No.61-MEQ-1528, MOC: ASTM A -351-CF8, C: 0.08% MAX., Si:1.5% MIN., Ni:8-10%, Cr.:16.5-18.5%, Mo: 2-3%.	2.00
	NOTE: i		MATERIAL SHALL BE MANUFACTURED UNDER THIRD PARTY INSPECTION OF M/S. LRA/TUV//BV/EIL/PDIL	
	NOTE II		THE SCOPE OF THIRD PARTY SHALL BE:- (I) REVIEW OF CHEMICAL COMPOSITION (II) REVIEW OF PHYSICAL PROPERTIES (III) REVIEW OF DIMENSIONS AS PER DRAWING 61-SP-1528 (IV) WITNESS OF DYE PENETRATION TEST. (V) WITNESS OF HYDRAULIC TEST AT 10KG/CM2	
	NOTE 111		ALL TEST CERTIFICATES SHALL BE SIGNED AND STAMPED FROM INSPECTION PARTY.	
2	Guarantee/ Warrantee Certificates	You shall have to furnish a Guarantee / Warranty Certificate for your products against defective material / bad workmanship for a period of 12 months from the date of commissioning or 18 months from the date of dispatch, whichever is earlier. In case the material fails during the above Guarantee period due to defective material or bad workmanship, you will have to replace the same free of cost. Certificate must accompany the dispatch documents		

Sr.No.13427



GENERAL TOLERANCE - ± 0.10
 DIMENSIONS IN PARENTHESES - ± 0.05
 DIMENSIONS IN SQUARES - ± 0.05

PASSED FOR EXECUTION
 Name: _____
 Signature: _____
 Designation: Asst. Manager (Mech.)
 Date: 17.05.2011

MAT. ASTM - A - 351 - CP3

नेशनल फर्टिलाइजर्स लिमिटेड
 NATIONAL FERTILIZERS LIMITED

FOR ACID PUMP 124 - AIT

NO.	DATE	REVISION	BY	CHKD

6/25/1528

Sr.No.13427